

State Water Resources Control Board

October 5, 2017

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7015 1520 0001 7928 3263

Mr. David Brunolli
Chief of Plant Operations
California Highway Patrol
3500 Reed Avenue
West Sacramento, California 95605
dbrunolli@chp.ca.gov

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT THE CALIFORNIA HIGHWAY PATROL ACADEMY,
3500 REED AVENUE, WEST SACRAMENTO**

Dear Mr. Brunolli:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on September 27, 2017, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Plot Plan/Site Map – A plot plan/site map indicating the location of the product piping and sensor locations was not available in CERS or onsite at the time of inspection.	All	September 27, 2017	Ongoing	23 CCR 2711(a)(8)
2	Failure to Monitor Product Piping – The sensors in the turbine sumps were unable to detect a leak at the earliest opportunity because they were not located at the lowest point at the product line side of the sump.	All	September 27, 2017	Ongoing	CCR 23 2630(d)
3	Failure to Maintain Facility and Tank Information (Form B) – In CERS, under corrosion protection, isolation lists “no”, when it should list “yes”.	All	September 27, 2017	Ongoing	23 CCR 2711(a)

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

1001 I Street, Sacramento, CA 95814 | Mailing Address: P.O. Box 100, Sacramento, CA 95812-0100 | www.waterboards.ca.gov

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Yolo County Environmental Health within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov

Local CUPA

Ms. Moushumi Hasan
Supervising Hazardous Materials Specialist
Yolo County Environmental Health
292 West Beamer Street
Woodland, California 95695
moushumi.hasan@yolocounty.org

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: (via email only)

Ms. Moushumi Hasan
Supervising Hazardous Materials Specialist
Yolo County Environmental Health
moushumi.hasan@yolocounty.org

Mr. Ralph Wheeler
Operations Manager
California Highway Patrol
rwheeler@chp.ca.gov

Lt. Daniel Kirkpatrick
Acting Commander
California Highway Patrol
dkirkpatrick@chp.ca.gov

Mr. Mike Schmahl
California Highway Patrol
mschmahl@chp.ca.gov

Ms. Beth DePaola
California Highway Patrol
EDePaola@chp.ca.gov